



**Walsall Council**

**Wolverhampton City Council**

**Dudley Metropolitan Borough Council**

**Sandwell Metropolitan Borough Council**

**Regeneration and Transportation**

Drawing Title:
**WIRING IN COLUMN AND SIGN BASES
AND STEEL ARMOUR EARTHING**

DRAWN	APN	DATE	JUL/09
CHECKED	JBF	SCALE	NTS

Drawing Number
SD/1400/01

Rev
01

FRAMEWORK CONTRACT FOR HIGHWAY WORKS - MINOR WORKS CONTRACT

- NOTES
1.

ALL FUSED CUT-OUTS SHALL BE MANUFACTURED BY TOFCO-SMK (DPI SYSTEM OR EQUIVALENT AND APPROVED) AND PROVIDE DOUBLE POLE ISOLATION WITH LOCK OFF FACILITY.
2.

CABLES SUPPLYING A SIGNBOLLARD FROM A COLUMN SHALL BE SEPARATELY FUSED.
3.

FOR HRC FUSE RATINGS SEE APPENDIX 14/4.
4.

INTER CONNECTING WIRING SHALL BE SUITABLY RATED IN ACCORDANCE WITH THE CIRCUIT PROTECTIVE DEVICE (min. 4mm sq csa.).
5.

CABLE GLANDS TO DW TYPE SUCH AS HAWKE OR EQUIVALENT AND APPROVED.
6.

EARTH ELECTRODES SHALL BE INSTALLED WHERE NECESSARY TO MEET ELECTRICITY COMPANY'S REQUIREMENTS.

